

ROCKY FLATS ENVIRONMENTAL TECHNOLOGY SITE

REGULATORY CONTACT RECORD

Date/Time: 7/2/03 – 1300 p.m.

Site Contact(s): D. A. Parsons (D&D) – (DAP-013)
Phone: (303) 966-6458

Regulatory Contact: David Kruchek, CDPHE
Phone: (303) 692-3328

Agency: CDPHE

Purpose of Contact: Building 440 Anticipated Typing 2 Reconnaissance Level Characterization

Meeting Attendance

D. Parsons, RISS
K. Shuler, RISS
H. Linsinbigler, RISS

D. Kruchek, CDPHE
E. Bryson, RFFO

C. Freiboth, RISS
S. Tower, RFFO

Discussion

During the weekly RISS Area Status meeting held on Wednesday afternoon, 7/2/03, Duane Parsons (RISS) discussed the Building 440 Anticipated Typing 2 Reconnaissance Level Characterization (RLC). The historical and present use of the building was discussed, as was the various additions that have been added on to the building over time. It was discussed that the primary reason that the building was classified as an “anticipated” Type 2 RFCA facility was due to the drum repack room and the Permacon in Room 113. The remaining portions of the facility are not expected to contain residual radioactive or chemical contamination on facility surfaces.

Based on the above information, it was agreed that a combination RLC and Pre-demolition Survey (PDS) would be performed after the drum repack equipment and the Permacon in Room 113 was stripped out, and the rest of the building was readied for PDS. It was also agreed that floor coatings would be evaluated for undercoating contamination in suspect areas during the Building 440 PDS.

Contact Record Prepared By: D. A. Parsons

Required Distribution:

P. Arnold, K-H
C. Deck, K-H
R. DiSalvo, RFFO
C. Gilbreath, K-H
S. Gunderson, CDPHE
T. Hopkins, K-H
L. Kilpatrick, K-H
J. Legare, RFFO

R. Leitner, K-H
J. Mead, K-H
S. Nesta, K-H
K. North, K-H
W. Prymak, DOE
T. Rehder, USEPA
D. Shelton, K-H

Additional Distribution:

C. J. Freiboth, K-H
F. Gibbs, K-H
D. Kruchek, CDPHE
S. Tower, RFFO
J. Hindman, CDPHE
K. Wiemelt, K-H
E. Bryson, RFFO
H. Linsinbigler, K-H

